



Fuel Quality Services, Inc.



Certificate No. TRC 00346

P.O. Box 1380, Flowery Branch, GA 30542-0023 • Telephone: 800-827-9790 or 770-967-9790 • Facsimile: 770-967-9982 • Website: www.fqsinc.com

KATHON FP 1.5
SMALL TANK - TREATMENT RATIO

System Volume			Dose Volume		
Gallons	Liters	Cubic Meters	Ounces	Milliliters	Liters
50	189.25	0.19	0.75	22.18	0.022
100	378.50	0.38	1.5	44.36	0.044
150	567.75	0.57	2	59.14	0.059
200	757.00	0.76	2.75	81.32	0.081
250	946.25	0.95	3.5	103.50	0.103
300	1135.50	1.14	4	118.28	0.118
320	1211.20	1.21	4.25	125.67	0.126
350	1324.75	1.32	4.5	133.07	0.133
400	1514.00	1.51	5.25	155.24	0.155
450	1703.25	1.70	6	177.42	0.177
500	1892.50	1.89	6.5	192.21	0.192
1000	3785.00	3.79	13	384.41	0.384
1500	5677.50	5.68	19.5	576.62	0.577
2000	7570.00	7.57	25.75	761.44	0.761
2500	9462.50	9.46	32	946.25	0.946
3000	11355.00	11.36	38.5	1138.46	1.138
4000	15140.00	15.14	51.25	1515.48	1.515
5000	18925.00	18.93	64	1892.50	1.893
10000	37850.00	37.85	128	3785.00	3.785